

Memo

To: Robert R. Schaefer
From: Gene Pabst *GP*
CC: Randy Lyman, Bob Corson, Karen Chandler, Mark Murphy, and Dustin O'Neal
Date: 08/09/01
Re: Dye study of the old Sears building – 625 E. St. Louis.

On August 8, 2001 we did a dye study of the old Sears building at 625 E. St. Louis. We obtained the following results:

1st Floor - Snack Bar & Bathrooms to MH 5 (Wye Map O19-NW This manhole is inside the garage.)
Basement - Bathrooms & Boiler to MH 5 (Wye Map O19-NW)
Garage - Most of the floor drains in the garage were full of dirt. We were able to dye one drain but did not observe dye in the sanitary or the storm box. The garage area has a basement area. Entrance to the basement area is obtained by lifting a large metal plate and going down a short flight of stairs. Since this was a confined space, we did not enter the basement. We did shine a light in the area and could see some piping. We think that the floor drains of the garage might go to a central sump location and is pumped to the sanitary sewer. *No Bathroom in Garage GP*

The sanitary sewer line between MH 1 & MH 2 and the line between MH 2 & MH 3 (Wye Map O19-NW) is a dead line. MH 2 is at the shown location. This line has been disconnected from MH 3.

In the Boiler room drains go to a lift. The discharge from the lift is broken & water would discharge to the floor. We told the University Plaza maintenance worker about this and he said it has been this way for years.
GP

FROM THE DESK OF
J. RANDALL LYMAN
PRETREATMENT COORDINATOR
CITY OF SPRINGFIELD
1216 W. NICHOLS ST.
SPRINGFIELD, MISSOURI 65802
PHONE 417-864-1487
Fax 417-864-1918
e-mail randy_lyman@ci.springfield.mo.us
8/7/01

GENE, CAN YOU LOOK UP ANY OR ALL INFO.
WE MAY HAVE GENERATED OVER THE
YEARS IN THE VICINITY OF THE OLD SEARS
BUILDING ON E ST LOUIS? KEVIN IS
WORKING ON THIS FOR
BOB SCHAEFER AND INDICATES WE WILL
NEED TO DO A COMPLETE DYE TRACE OF
ALL DRAINS IN THE BUILDING IF NOT
AVAILABLE. I REMEMBER SOME DYEING
AT SEARS AND THOMPSONS SOME TIME AGO

THANKS, RANDY.







